4639279431

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gilbert Stroud DATE 3-2-76 PERMIT NO. 43

PHONE: Business _____ Home 873-8338

LOCATION 1303 North Th on 1300 TR on 1st Rd 1½ mi on left S. R. No. 1471

SUBDIVISION NAME CL+T LOT NO. 82 SECTION OR BLOCK NO. 16

Site Address: 248 Tennessee Circle - Mrsvl

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 3/4 acre


Character & Porosity of Soil Clay loom Porosity Fair

Percolation Rate Not taken

Topography 290 to 320 Slope on lin

Depth to Water Table 10'+

Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Hoke Septic Tank Co.

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 3-2-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold