4639279431

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gilbert Stroud DATE 2-2-06 PERMIT NO. 43

PHONE: Business _____ Home 704-929-5254

LOCATION 1203 North TL on 1300 TR on 1st Rd
½ mi on left S. R. No. 1107


SUBDIVISION NAME _____ LOT NO. 82 SECTION OR BLOCK NO. 11

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes ( ) No (✓)
Site Suitable Yes (✓) No ( )
Lot Area 3/4 acre

Character & Porosity of Soil Clay loam Porosity Fair
Percolation Rate 30 min taken
Topography 3% to 5% slope on lot
Depth to Water Table 10'+
Rock or other impervious formations none

Lake



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 425 Linear Ft. 250
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Well

Installed by Hoke Septic Tank Co.

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 2-2-06

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold