DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Fall Cove Dev, LLC
ADDRESS: _____ APPLICATION DATE _____
PROPOSED FACILITY: 4 BR SFD PROPOSED DESIGN FLOW (.1949): 480 GPD DATE EVALUATED: 03/13/07
LOCATION OF SITE: Lot 628 offsite area (681) PROPERTY SIZE: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____ PROPERTY RECORDED: _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1949 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 REST. HORIZ.	PROFILE CLASS & LTAR
1	L	0-8	Gr, SL	VFr, SS, NP (Brwn)					PS
		8-28	Mo, sbk, C	Fr, SS, SP (Red)					
		28-45	Mo/wk, sbk, CL	Fr, SS, SP (Red)					0.30
		45-56	wk, sbk, CL	Fr, SS, SP (Red)	C-sap				
2	L	0-7	Gr, SL	VFr, SS, NP (Brwn)					PS
		7-29	Mo, sbk, C	Fr, SS, SP (Red)					
		29-43	wk, sbk, CL	Fr, SS, SP (Red)					0.30
		43-57	wk, sbk, CL	Fr, SS, SP (Red)	C-sap				
3		0-10	sbk scl	fr sss sp					.30
		10-43	mo sbk C	fr sss sp					
		43-54	wk sbk CL	fr sss sp	f-sap				
4	7%0	0-7	gr sl	vfr ss np					.30
		7-26	mo sbk C	fr ss sp	Red				
		26-49	wk sbk C	fr sss sp	fair-com sap				
		49-58	massive	Loam sap	few cl pockets				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
vailable Space (.1945)		
ystem Type(s)		
le LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

MMENTS: _____