13674

IREDELL COUNTY HEALTH DEPARTMENT

4639 30 3955

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Thomas W Steele DATE 11/15/91 PERMIT NO 25-5-A-21

PHONE: Business _____ Home 996-2097

LOCATION Kenway Loop, TL at Bells Chapel Roads, onto Fern Hill TL on Bagley, TL on Kenway Loop, 1/8 mile on (R)

SUBDIVISION NAME LAKE NORMAN S. R. No. _____

LOT NO. 1028 SECTION OR BLOCK NO. 15

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil P-


Percolation Rate .4

Topography 15%

Depth to Water Table >48"

Rock or other impervious formations none observed

Lot Area 1ac.



Plot of System

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 3 @ 100' x 3' 300 Lin Ft

Sq. Ft ~~600~~ Linear Ft. ~~250~~

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____

EXISTING SYSTEM CHECKED BY: Wesley Sparks RS. DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS. DATE 11/15/91

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold