Earl Hicks

IREDELL COUNTY HEALTH DEPARTMENT

II 4639 30.5013

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

231

OWNER OR CONTRACTOR Earl Hicks DATE 2-7-12 PERMIT NO. 230

PHONE Business _____ Home _____

LOCATION [illegible] S. R. No. [illegible]

SUBDIVISION NAME [illegible] LOT NO. 25 SECTION OR BLOCK NO. 15

House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1 Character & Porosity of Soil Sandy Clay Loam


Garbage Disposal Unit Yes ( ) No (✓) Percolation Rate 30 min/in

Auto. Dishwasher Yes ( ) No (✓) Topography Rolling

Auto. Wash. Machine Yes ( ) No (✓) Depth to Water Table 10 ft

Site Suitable Yes (✓) No ( ) Rock or other impervious formations None

Lot Area [illegible]



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 120 Linear Ft. 200

Depth of Stone in Lines 24

Water Supply: Individual (✓)

Public ( )

Installed by [illegible]

IMPROVEMENTS PERMIT BY [illegible]

COMMENTS: _____

CERTIFICATE OF COMPLETION BY [illegible] DATE 2-7-12

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold