IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 202755

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4639327652 9686

APPLICANT: Dave Grays APPLICANT ADDRESS: 631 Brawley School Rd #200B Mooresville, NC

SITE ADDRESS: 133 Blue Ridge Trail Mooresville, NC PHONE: ALT. PHONE:

SITE DIRECTIONS: Perth Rd N on TL Fern Hill TL Blue Ridge Trail 9th lot on left

SUBDIVISION: Wood leaf (5-27-13) SECTION: LOT # 9/10 LOT AREA: DESIGN FLOW: 480gpd L.T.A.R.: .3

Septic Tank	1000 (gal)	STB	1012	Date	9-30-13	☒ New System	☐ Repair ☐ Expansion	System Type: I II III IV V VI	☒ Residence	No. Bedrooms	4	Water Supply			
Pump Tank	1000 (gal)	PT	17	Date	9-30-13	System Description	Pump-PM-25% Reduction LPP BPS		☐ Business	No. Persons	8	☒ Private			
Pump Make	Myers	Model	ME505-2	Serial#	10062084	Repair System Description:			☐ Other	No. Employees		☐ Public			
# Nitrification Fields	1	# Lines	5	Linear Ft:	400'	Maintenance Agreement Required:	☐ YES	☒ NO	☐ Slab	☐ Crawl Space		☐ Community			
Trench Width	36"	Max. Trench Bottom Depth	36"	Gravel Depth	N/A		☒ GRAVITY	☐ PRESSURE	☐ Basement w/plumbing		☐ Basement w/o plumbing				

Comments / Conditions: This permit replaces previous permits from Aug. 2006. *OK to put tanks on side of house, 100ft to well, 10ft to PL

*Do Not issue Authorization to Construct until Combination of lots is recorded. Combination of lots recorded 4/21/14, deed attached 7/30/14 Checked tanks & Supply line.

INITIAL SITE SKETCH

See attached approved plan by Kathleen Saunders

AS BUILT SKETCH

11/4/14 Set 2ft pressure

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☐ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☐ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: David Grays Date: 5/7/14 Installed by: Steve Jordan Piedmont

IMPROVEMENT PERMIT by: Date: 4/16/14 OPERATION PERMIT by: Date: 11/4/14

AUTHORIZATION TO CONSTRUCT by: Date: 4/23/14 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK

OK to Install drainline here
126.69'
138.65'
377.78'
461.39'
OK MP 4/14/14
55' Repair
65' Repair
75' Repair
90' Repair
10-1
10-2
Add. Repair Area
Add. Repair Area
Lot
Lot
Pool
PRELIMINARY PLAT
NOT FOR RECORDATION,
CONVEYANCES, OR SALES.
15' SETBACK
15' SETBACK
35' SETBACK
35' SETBACK
35' SETBACK
100'
100'
BLUE RIDGE TRAIL
50' Public R/W
1" = 50'
N