RTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
SION OF ENVIRONMENTAL HEALTH
-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 5-6-04
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 480gpd PROPERTY SIZE: _____
LOCATION OF SITE: Lot 1 Beacon Pt Phase 4 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	2% S.V	0-30	mf sbk RCl	fr SS SP	common mi/sap				3
		30-40	(B,C) wk f sbk/massive scl	fr SS SP					
		40-52	massive / SL	SAP fr SS SP					
2		0-11	mf sbk RDBrC	fr SS SP SAP	SAP common mi/sap				.3+
		11-46	(B&C) f sbk RYSCL	fr SS SP					
		46-60	massive Wet SL	SAP fr SS SP					
3		0-18	mf sbk RCl	fr SS SP SAP	common mi/sap				.3+
		18-31	wk f sbk RYSCL	fr SS SP					
		31-65	massive light olive brown L/SL	SAP fr SS SP					
4		0-2	gr leaf scl	fr					.3+
		2-14	mf SBK/f sbk RDBrC	fr SP SAP					
		14-26	wk f sbk/massive YR scl	fr SS SP					
		26-62	massive dry SL	SAP fr SS SP MP					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	Gravity Conv.	Gravity pumped conv
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): RS
EVALUATED BY: [signature]
OTHER(S) PRESENT: Paul Pennington