IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Mr. Raymond H DATE 10-8-93 PERMIT NO. 256

PHONE: Business _____ Home 523-3704

LOCATION 150 west TR on 1303 4.5 mi TL on 1300 1 mi TR on 1471 ½ mi on right S. R. No. 1471


SUBDIVISION NAME Duke Power LOT NO. 86 SECTION OR BLOCK NO. 11

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clay loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	30 min/in
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	slight slope toward lake
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	2'
			Rock or other impervious formations	none

Lot Area 150 X 203



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 630 Linear Ft. 255
Depth of Stone in Lines 18
Water Supply: Individual (✓)
Public ( )

Installed by E.J. Ervin

IMPROVEMENTS PERMIT BY J. C. Mabrey

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Mabrey DATE 10-20-93

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold