3-3-50

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Richard Lee Tyerby DATE 6-10-87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1303 N. TR 1300 (Fern Hill) TR Tennessee Circle
⅛ mile on Rt

S. R. No. _____

SUBDIVISION NAME L.N. LOT NO. 930 SECTION OR BLOCK NO. 16

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes ( ) No ( )

Lot Area ~1 AC

Character & Porosity of Soil clay


Percolation Rate ~.40

Topography 2-6%

Depth to Water Table 4'

Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 400 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

X Signed: Rick L. Tyerby

IMPROVEMENTS PERMIT BY J.R. Harris, RS, Andrew C. Pierce

COMMENTS: Follow contour. Install drainfield w/ 15" cover. Pressure dose conventional line. Call Health Dept for specs before installing system.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold