4639387269

II

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Charles Campbell DATE Sept 1, '78 PERMIT NO. 210

PHONE: Business / Home 873-1717

LOCATION 1303 N T.L. on 1403 3rd lot from end

S. R. No.

SUBDIVISION NAME Lake Norman LOT NO. 125 SECTION OR BLOCK NO. 16

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 1.7 ac


Character & Porosity of Soil clay loam

Percolation Rate 60 mpi

Topography 4-6 %

Depth to Water Table 6-8'

Rock or other impervious formations none obs.



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 600 Linear Ft. 200

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Herlee Lackey

IMPROVEMENTS PERMIT BY John Houston

COMMENTS:

CERTIFICATE OF COMPLETION BY David R. Hinson DATE Sept 1, '78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold