Department of Environment, Health, and Natural Resources
Division of Environmental Health
On-site Wastewater Section

Sheet: **1 OF 1**
PIN #: **4639-41-7466**
Lot #: **3**
Permit #: **176959**
AppID:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: **STEPHEN WILLIAMS**
Address: **241 KENWAY LP**
Proposed Facility: **SFR** Design Flow (.1949) **720 GPD**
Location of Site: **CL&T-15-3**
Water Supply: [ ] Public [X] Individual [X] Well [ ] Spring [ ] Other
Evaluation Method: [X] Auger Boring [ ] Pit [ ] Cut
Type of Wastewater: [X] Sewage [ ] Industrial Process [ ] Mixed

Applicant: **KENT SHAW & SONS**
Date Evaluated: **3/13/2013**
Property Size: **.92 AC**
Property Recorded: **YES**

PROFILE #	1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY 1941		b PROFILE FACTORS				Profile Class & LTAR
			1941 Structure/ Texture	1941 Consistence Mineralogy	1942 Soil Wetness/ Color	1943 Soil Depth (IN.)	1956 Sapro Class	1944 Restr Horiz	
AB 1	LINEAR 5%	0-12	SAND,GR	NS	NA	48"	NA	48+	.35
		12-30	C,M,SBK	SS					
		30-48	CL,M,SBK	SS					
AB 2	LINEAR 5%	0-12	SCL,W,SBK	SS	NA	48"	NA	48+	.35
		12-48	CL,M,SBK	SS					
AB 3	LINEAR 5%	0-6	ORGANIC		NA	48"	NA	48+	.35
		6-40	C,M,SBK	SS					
		40-48	CL,M,SBK	SS					

Description	Initial System	Repair System
Available Space (.1945)	PS	PS
System Type(s)	G-25%	TS-2 PANEL
Site LTAR	.35	.35

Other Factors (.1946):

Soil Evaluation By: **BEN ALDRIDGE**
Others Present: **KENT SHAW**
Site Classification (.1948): **PS**
Site Evaluation By: **BEN ALDRIDGE**
Others Present: **KENT SHAW**