375

# IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

## IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 135463 PIN# 4639209711.039 4639-42-5294 DATE June 8, 2006

OWNER OR APPLICANT Woodbridge Partners / Walt Ward. PHONE: Business _____ Home _____

ADDRESS P.O. Box 3608, Mooresville, N.C. 28117

LOCATION Perth Rd. (N) TL Fern Hill TL Kenway Loop on Right

SUBDIVISION Woodleaf BLOCK / SECTION _____ LOT 39 LOT AREA 1.211 Ac SITE CLASS. PS DESIGN FLOW 480 gpd L.T.A.R. .3 initial / .25 Repair

Septic Tank: 1000 Gallons; STB 1012 Date 10-20-06

Pump Tank: 1000 Gallons; PT 17 Date 3-19-07

Pump Make: Gouids Model PESIM Serial No. CO743408

Nitrification Field: No Fields 1 Square Feet 540 Linear Feet 270

No Lines 4 Trench Width 24" min, 8'oc Max Trench Bottom Depth 36" Gravel Depth NA ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III (IV) V VI

System Description: LPPPBPS

Repair System Description: LPPPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons ____ No. Employees ____

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions:

Comments/Conditions:

yellow tuf-tite filter

Tanks checked 5-8-07 jm

lines checked 5-8-07

pressure checked 5-8-07

INITIAL SITE SKETCH

SEE PLAN from S&ME

AS BUILT SKETCH

System installed as per site sketch

Line Lengths

40', 56', 86', 86'

gvb at upper line

The location of the proposed Pool (see site plan) addition does not appear to impact the existing septic system.

**NOTE: Must be 15' min. from ST & PT (Tanks)

10' min. from supply line

REHS

Date Judy Melville REHS 2-8-11

ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with ~~plat~~ valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 6-20-06

Improvement Permit by: _____ date 6-8-06

Authorization to Construct by: _____ date 11/9/06

Installed by: Tommy Fryar

Operation Permit by: Wesley Sparks RS. date 7/12/07

Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK