IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 177864

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4639 43 1434

APPLICANT: Michael Athanas / Pacitti APPLICANT ADDRESS: 1999 Candlewick Dr

SITE ADDRESS: 129 Kenway Lp Mooresville 28117 PHONE: 704-576-3887 ALT. PHONE:

SITE DIRECTIONS: Perth Rd N TL Fern Hill TL Kenway LP on left

SUBDIVISION: Wildwood Cove SECTION: LOT # 38 LOT AREA: 2.093 Ac. DESIGN FLOW: 480 gpd L.T.A.R.: .3 gpd/ft²

Septic Tank Existing (gal) STB Date

Pump Tank (gal) PT Date

Pump Make Model Serial #

Nitrification Fields 1 # Lines 2 Linear Ft: 200

Trench Width 30" Max. Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI

System Description: 25% Reduction

Repair System Description: Drip Irrigation .1 gpd/ft²

Maintenance Agreement Required: ☐ YES ☒ NO

☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 4

☐ Business No. Persons

☒ Other Pool No. Employees

☐ Slab ☒ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions:

- Relocation of 2 septic lines for Pool
- Pool shall be min. 15' from nearest edge of septic drain line

INITIAL SITE SKETCH

See Plan From
Michael Athanas & Assoc.
Approved by ICHD

AS BUILT SKETCH

INSTALLED AS SHOWN ON
PLAN
D-Box Removed
Drop Boxes Installed
Use End Caps on 2 New Lines

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** ***with plat*** *valid without expiration.* ☒ **IMPROVEMENT PERMIT** ***with site plan*** *valid for 60 mos.* ☒ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: Installed by:

IMPROVEMENT PERMIT by: Judy Melville Date: 4-5-13 OPERATION PERMIT by: R&H BATES Date: 4-11-13

AUTHORIZATION TO CONSTRUCT by: Judy Melville Date: 4-5-13 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK