IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 178160

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4639-43-9079

APPLICANT: KENNETH CROZIER APPLICANT ADDRESS: 3101 AQUA MARINE BLVD, AVON LAKE, OH 44012

SITE ADDRESS: 185 WILDWOOD COVE RD PHONE: 440-213-1344 ALT. PHONE:

SITE DIRECTIONS: PERTH, FERNHILL, TL WILDWOOD COVE, ON L

SUBDIVISION: WILDWOOD COVE SECTION: LOT # 7 LOT AREA: 1.1 AC DESIGN FLOW: 480 L.T.A.R.: .13

Septic Tank	1000 (gal)	STB	825	Date	9-23-13	☒ New System	☐ Repair	☐ Expansion	System Type: I II (III) IV V VI	☒ Residence	No. Bedrooms 4
Pump Tank	(gal)	PT		Date		System Description:	25% REDUCTION			☐ Business	No. Persons
Pump Make		Model		Serial #		Repair System Description:	SHALLOW PANEL			☐ Other	No. Employees
# Nitrification Fields	1	# Lines	4	Linear Ft:	400'	Maintenance Agreement Required:	☐ YES	☒ NO		☐ Slab	☒ Crawl Space
Trench Width	36"	Max. Trench Bottom Depth	36"	Gravel Depth		☒ GRAVITY	☐ PRESSURE			☐ Basement w/ plumbing	☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions: 7/3/13 Reviewed Floor plans, in Compliance with orginal plans. House is slightly larger than origin but still will fit.

(Note: Drive on other side (No full bath by Bonus room)

INITIAL SITE SKETCH

SEE ATTACHED PLAN BY MICHAEL ATHANAS & ASSOCIATES APPROVED BY ICHD

AS BUILT SKETCH

30
16 SEE
26 AS BUILT
15 DRAWING
13

Location of the proposed Pool addition does not appear to impact the existing on-site septic system.**NOTE: Shall be min. 15' from Septic Tank & system

Cindy Melville REHS

Date: 11-08-13

ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat* valid without expiration. ☒ **IMPROVEMENT PERMIT** *with site plan* valid for 60 mos. ☐ **AUTHORIZATION TO CONSTRUCT** valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.

Owner / Applicant Signature: Date: 5-1-13 Installed by: ROWAN SEPTIC

IMPROVEMENT PERMIT by: Date: 4-25-13 OPERATION PERMIT by: Date: 11-22-13

AUTHORIZATION TO CONSTRUCT by: Date: 7/3/13 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK