IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 178160

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4639-48-9079

APPLICANT: KENNETH CROZIER APPLICANT ADDRESS: 3101 AQUA MARINE BLVD, AVON LAKE, OH 44012

SITE ADDRESS: 185 WILDWOOD COVE RD PHONE: 440-213-1344 ALT. PHONE:

SITE DIRECTIONS: PERTH, FERNHILL, TL WILDWOOD COVE, ON L

SUBDIVISION: WILDWOOD COVE SECTION: LOT # 7 LOT AREA: 1.1 AC DESIGN FLOW: 480 L.T.A.R.: 13

Septic Tank 1000 (gal) STB 325 Date 9-23-13
Pump Tank (gal) PT Date
Pump Make Model Serial #
Nitrification Fields 1 # Lines 4 Linear Ft: 400'
Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth

☒ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI
System Description: 25% REDUCTION
Repair System Description: SHALLOW PANEL
Maintenance Agreement Required: ☐ YES ☒ NO
☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 4
☐ Business No. Persons
☐ Other No. Employees
☐ Slab ☒ Crawl Space
☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions: 7/3/13 Reviewed floor plans, in Compliance with original plans. House is slightly larger than original but still will fit.

(Note: Drive on other side. (No full bath by Bonus room)

INITIAL SITE SKETCH

SEE ATTACHED PLAN BY MICHAEL ATHANAS & ASSOCIATES APPROVED BY ICHD

AS BUILT SKETCH

30
16 SEE
26 AS BUILT
15 DRAWING
13

Location of the proposed Pool addition does not appear to impact the existing on-site septic system.**NOTE: Shall be min. 15' from Septic Tank & system

Cindy Melville REHS
Date: 11-08-13
ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☒ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☐ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 5-1-13 Installed by: Rowan Septic

IMPROVEMENT PERMIT by: Date: 4-25-13 OPERATION PERMIT by: Date: 11-22-13

AUTHORIZATION TO CONSTRUCT by: Date: 7/3/13 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK