DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ____ *of* ____
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _Mike @ Lake Realty_____ APPLICATION DATE_____
ADDRESS:_____ DATE EVALUATED: _____
PROPOSED FACILITY: 4 Bedroom_____PROPOSED DESIGN FLOW (.1949): 480 gal._____ PROPERTY SIZE: _____
LOCATION OF SITE: __Wildwood Cove lot 7_____ PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☒ Pit ☐ Cut TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				PROFILE CLASS & LTAR
			.1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	
pit 1	LS 2-4%	0-25	R C SBK	FR SS SP	Few incl. WR and SAP	48"			PS 0.3
		25-48	R CL WSBK	FR SS SP					
pit 2	LS 3-5%	0-26	R C SBK	FR SS SP	Few SAP incl	53"			PS 0.3
		26-53	R CL SBK	FR SS SP					
pit 3	LS 2-4%	0-12	Br SCL WSBK	FR SS SP		40"			PS 0.3
		12-40	R C SBK	FR SS SP					
		40	WR						
pit 4	LS 5%	0-27	R C SBK	FR SS SP	Few WR incl.	55"			PS 0.3
		27-55	R CL WSBK	FR SS SP					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	1200 ft2	540 ft2
System Type(s)	25% Reduction	PPBPS
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _M A & Assoc._____
OTHER(S) PRESENT: _____

COMMENTS:_____

SOIL/SITE EVALUATION

(Continuation Sheet)

Sheet ____ of ____

DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

PROPERTY ID #: ____________
DATE OF EVALUATION: ____________
COUNTY: ____________

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				PROFILE CLASS & LTAR
			.1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	
AB 3	LS 5%	0-24	R C SBK	FR SS SP		48"			PS 0.3
		24-48	R CL WSBK	FR SS SP					

COMMENTS: ____