IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 092381 PIN# ~~4639 73 4457 (pt.)~~ 4639-44-1230 DATE Feb 12, 01

OWNER OR CONTRACTOR Crescent Resources Inc. / J.S. Regis LLC PHONE: Business 704-509-9100 Home

ADDRESS P.O. Box 1003 Charlotte 28201

LOCATION Perth Rd. N. TL Fernhill Rd. TL Wildwood Cove Dr. on left

SUBDIVISION Wildwood Cove BLOCK / SECTION LOT 2 LOT AREA 43,310 ft² SITE CLASS. PS DESIGN FLOW 480 gpd L.T.A.R. ~.25

Septic Tank: 1000 Gallons; STB 794 Date 4/31/02

Pump Tank: 1000 Gallons; PT 29 Date 4/31/02

Pump Make: MYERS Model ME50S-11 Serial No. —

Nitrification Field: No Fields 1 Square Feet 1890 Linear Feet 630

No Lines 7@90 Trench Width 36" Max Trench Bottom Depth 24" Gravel Depth 12"

☑ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: PM - Conventional

Repair System Description PM - Innovative 25% Red.

Maintenance Agreement Required: ☐ Yes ☑ No

☑ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4/4 No. Bathrooms 4/4 No. Employees

Water Supply: ☑ Individual ☐ Public ☐ Community

☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

Comments:/Conditions: Risers, Tanks, Pressure

1" = 50'

375' INITIAL SITE SKETCH

Low Drainageway

Intermittent

Divert Stormwater Around Home Site

2" Sch 40

DRIVEWAY

House Site

60'

40'

REPAIR AREA

WELL

100'

270'

AS BUILT SKETCH

Sch 80 pvc

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: [signature] date 3-21-01

Improvement Permit by: [signature] date 2-12-01

Authorization to Construct by: [signature] LSI date 11/8/01

Installed by: Orbin Conn & Co.

Operation Permit by: Wesley Sparks RS. date 7/30/02

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK