4039453473

IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 176173

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4639453589

APPLICANT: PLATTNER BUILDERS APPLICANT ADDRESS: PO BOX 1138 DAVIDSON

SITE ADDRESS: 112 NAUTICAL PT CT MOORESVILLE PHONE: ALT. PHONE:

SITE DIRECTIONS: FERN HILL - TR NAUTICAL PT - AT END

SUBDIVISION: NAUTICAL PT SECTION: LOT # 10 LOT AREA: 6.8 AC DESIGN FLOW: 240 L.T.A.R.: 3

Septic Tank 1000 (gal) STB T194 Date 7-28-13
Pump Tank 1000 (gal) PT 283 Date 8-9-13
Pump Make Gould's Model WE0312M Serial #
Nitrification Fields 1 # Lines 2 Linear Ft: 200
Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth NA

☑ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI
System Description: PUMP 25% REDUCTION
Repair System Description: SAME
Maintenance Agreement Required: ☐ YES ☑ NO
☐ GRAVITY ☑ PRESSURE

☑ Residence No. Bedrooms 2
☐ Business No. Persons 4
☐ Other No. Employees
☐ Slab ☑ Crawl Space
☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☑ Private ☐ Public ☐ Community

Comments / Conditions: DO NOT ISSUE A/C UNTIL EASEMENT IS RECORDED PROPERLY. EASEMENT RECORDED
X Lots of rock in tank pit 8/30/13

Quick 4 installed as shown

INITIAL SITE SKETCH

SEE MICHAEL ATHANAS & ASSOCIATES PLAN.

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☑ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☐ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 8/29/13 Installed by: R&H RS

IMPROVEMENT PERMIT by: Date: 8/26/13 OPERATION PERMIT by: Date: 10/17/13

AUTHORIZATION TO CONSTRUCT by: Date: 8/30/13 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK