4639 45 5164

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 143702 PIN# 4639 55 0682.000 DATE August 20, 2007

OWNER OR APPLICANT Tegland-Brown Construction, Inc. / Mike Jo PHONE Business Home

ADDRESS 19550 Weavers Circle, Cornelius, N.C. 28031

LOCATION Poett Rd. (N) TL Fern Hill Rd. TR Hawks Nest Lane 2nd lot on left

SUBDIVISION Woodstream Estates BLOCK / SECTION LOT 2 LOT AREA .86 Ac +.43 Ac SF SITE CLASS. PSSF DESIGN FLOW 480 gpd L.T.A.R. .3 STE 2A

Septic Tank: 1000 Gallons; STB 312 Date 10-7-07

Pump Tank: 1000 Gallons; PT 283 Date 12-15-07

Pump Make Myers Model ME100 1HP Serial No.

Nitrification Field: No Fields 1 Square Feet 810 * Linear Feet 270

No Lines 3@90' Trench Width 36" * Max Trench Bottom Depth 36"

☒ New System ☐ Repair ☐ Expansion System Type: I II III (IV) V VI

System Description: LPP PBDS

Repair System Description: LPP PBDS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

Gravel Depth N/A ☐ Gravity ☒ Pressure ☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☒ Basement wo/plumbing

Comments:/Conditions:

* Per plan Specs

max. depth for tanks is 3 ft.

INITIAL SITE SKETCH

SEE Plan from Rollins Soil + Env. Services

Comments:/Conditions: 1/16/08 Checked at lowermost line.. Main floor powder room, needs to be verified to not have a tub only 1/2 bath.

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Mike Tegland date 8-22-07

Improvement Permit by: [signature] date 8-20-07

Authorization to Construct by: Cindy Merrell date 11-27-07

Installed by: Richard Abernathy

Operation Permit by: Maria Soto date 4/25/08

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK