Department of Environment, Health, and Natural Resources
Division of Environmental Health
On-site Wastewater Section

Sheet: 2 of 2
File #:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM
CONTINUED

PROFILE #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941 .1941 Structure/ Texture	.1941 Consistence Mineralogy	OTHER PROFILE FACTORS .1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR
AB	LINEAR	0-24	SCL,W,SBK	SS,SP,SEXP,VFR	NA/RED				
#1	14%	24-38	SC,M,SBK	SS,SP,SEXP,FR	NA/RED				
		38-49	SCL,M,SBK	SS,SP,SEXP,FR	NA/RED, FEW MICA				
		49+	CL,W,SBK	SS,SP,SEXP,VFR	NA/R/B/CSAP	49"		NA	.35
AB	LINEAR	0-15	SCL,M,SBK	SS,SP,SEXPVFR	NA				
#2	21%	15-29	SC,M,SBK	SS,SP,SEXPFR	NA				
		29-36	CL,W,SBK	SS,SP,SEXP,VFR	NA				
		36-40	SCL,W,SBK	SS,SP,SEXP,VFR	NA				
		40-57	LSAP,MASS	NS,NP,VFR	NA				
		57-61	SLSAP,MASS	NS,NP,VFR	NA	40"	S	NA	.35