DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Thornton Brooks APPLICANT: Semo
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 5/24/95
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: Tennessee Cir, on L before "Y" PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

(Lot 39 Northwood Front)

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	39 S | L 9-10% Rolling	0-7	GR | sl	FR SS - NP	B				
		8-18	MS SBK | C	FR SS - SP	R				
		19-34	MM SBK | cl	FR SS - SP					
		35-48	MF SBK | l	VFR - SS - NP	PS | R4				
2	40 7-8% L	0-5	GR | sl	VFR - SS -					
		6-39	SBK | cl	FR SS - SP.	PS | R4				
		40-48	GR | l	VFR SS - NP	PS | R				
3	41	0-12	MFGR | cl	VFR - SS - NP	P | 4				
		13-26	SC SBK | Cl	FR - SS - SP	| R				
		27-35	MM SBK | Cl	FR SS - SP	| R				
		36-	MF SBK | cl	VFR SS - NP	| MR			Sequum Cl	
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____