IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Kenneth Fox DATE 5-12-78 PERMIT NO. 83

PHONE: Business _____ Home 453-0248


LOCATION 1303 TL on 1403 ½ mi from end on left

SUBDIVISION NAME L A LOT NO. 123 SECTION OR BLOCK NO. C S. R. No. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Sandy Clay loam
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	30 min/in
Auto. Wash. Machine	Yes ( )	No (✓)	Topography	2 to 5% Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	6' to 8'
Lot Area 1 acre			Rock or other impervious formations	None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Dan Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 5-12-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold