DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___
463948 0340


SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Neal Parker APPLICANT: Neil Parker
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 3/2/05
PROPOSED FACILITY: House PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: .78
LOCATION OF SITE: Neil Farm Rd – Lot Northwood Ph 2 PROPERTY RECORDED: ___
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-5	sbk | cl	FR SS-SP	M | B				.25
		6-16	wk | hcl	FR MIC SS-SP	D | R				(.3)
		17-32	sbk | cl	FR SS-SP	M | R4				.35
		33-40	VFSBK | l-cl SAP	FR MIC SAP SS-SP					
		41-48	FiGR | scl SAP	VFR MIC SS-NP.					
2									
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___


126
'5
123
122
C3
C4
C5
C6
C7
L18
Lot
0.85
N77°11'35"E
250.54'
Lot
0.75 AC.
N77°46'11"E
239.41'
133.0
Lot
0.78 AC.
175.11'
N12°48'05"
1"=50'

DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: [redacted]
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Neil Parker APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 6/5/0
PROPOSED FACILITY: ___ PROPOSED DESIGN FLOW (.1949): ___ PROPERTY SIZE: ___
LOCATION OF SITE: Lot 22 Northwood PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	Initial	0-5"	Rd/Brn SCL	w/SBK	SS,SP,SE,F-FRw/few to many SAP Inclus				PS .3
		5-36"	Rd/Brn C/CL	m-wSBK					
		36"-48"	Yel/Rd	SL	SAP				
2	Repair	0-6"	Rd/Brn SCL/CL	wSBK	SS,SP,SE,F-FRw/ Mica Flakes & SAP Inclus				PS .3
		6-32"	Rd/Brn	C/C m-wSBK					
		32"+	Yel/Rd	SL	SAP				
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___