4639481068

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bill Coleman DATE 10/26/79 PERMIT NO. 372

PHONE: Business _____ Home _____

LOCATION 1303N TL 1403 near end on left


S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 122 SECTION OR BLOCK NO. 16

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	30 min/in
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	4-6%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4' +
Lot Area ~½ acre			Rock or other impervious formations	NONE OBSERVED



Plot of System

Size of Tank EXISTING 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"

Water Supply: Individual (✓)
Public ( )

Installed by Clontz Builders

IMPROVEMENTS PERMIT BY David R Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clontz DATE 10/26/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold