4639483113

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James A. Brady Jr. DATE 12-18-85 PERMIT NO. 320

PHONE: Business _____ Home _____

LOCATION 150 W TR 1303 TR 1403 About 1/3 mile ON left

S. R. No. _____

SUBDIVISION NAME LAKE NORMAN LOT NO. 121 SECTION OR BLOCK NO. 16

House ( ) Mobile Home (X) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2


Garbage Disposal Unit Yes ( ) No (X)
Auto. Dishwasher Yes (X) No ( )
Auto. Wash. Machine Yes (X) No ( )
Site Suitable Yes (X) No ( )

Lot Area Existing

Character & Porosity of Soil _____
Percolation Rate _____
Topography Existing System
Depth to Water Table _____
Rock or other impervious formations _____

8-3-1972

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



1090
Size of Tank Existing Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 225
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public ( )

8-3-1972
Installed by Raymond Adams

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: X

System checked by E. A. Stevenson 8-3-1972

IMPROVEMENTS PERMIT BY _____

COMMENTS: Existing System working OK At date of inspection

(X) well

Road 1403

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: Paul Clemmer DATE 12-18-85

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold