4639-48-7374 315 Winding Shore Rd at Aqua

12690

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Kenny Morris DATE 4/2/91 PERMIT NO. 3F-1-A-118

PHONE: Business _____ Home _____

LOCATION 1303 N. TR 1403 (Neill Farm Rd.) 1.2 miles on left S. R. No. _____

SUBDIVISION NAME CL&T LOT NO. 924 SECTION OR BLOCK NO. 16


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2-3
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil _____
Percolation Rate _____
Topography _____
Depth to Water Table _____
Rock or other impervious formations _____

Lot Area Existing

✓ Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

1000 pt Existing
Size of Tank 1000 ST Gals.
Nitrification Field:
No. of Lines 3 Existing
Sq. Ft. 1035 Linear Ft. 345
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DEH

COMMENTS: Existing system showing no sign of malfunction at time of inspection. System installed in 1988 in name of Michael Morris.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: DEHanson / EHS DATE 4/2/91

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold