IREDELL COUNTY HEALTH DEPARTMENT 4639502569

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR George Carr DATE 6-29-81 PERMIT NO. 196

PHONE: Business _____ Home _____

LOCATION 1303 N. TL 1399 ~ 1/2 mi. on left

S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 129 SECTION OR BLOCK NO. 14

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area ~ 3/4 Ac.

Character & Porosity of Soil _____
Percolation Rate _____
Topography _____
Depth to Water Table _____
Rock or other impervious formations _____

___ Basement with Plumbing ___ Basement without Plumbing ___✓___ No Basement



Plot of System

Size of Tank Existing Gals.
Nitrification Field:
No. of Lines Existing
Sq. Ft. _____ Linear Ft. _____
Depth of Stone in Lines _____
Water Supply: Individual ( )
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: Existing system working OK at time of inspection.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: David R. Hinson DATE 6-29-81

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Mike Parker DATE 4-10-01 PERMIT NO. 95

PHONE: Business _____ Home _____

LOCATION 150 west FR on 1307 Cross Lake Rd on 1399 on left before end of Rd S. R. No. 1399

SUBDIVISION NAME Lake Norman LOT NO. 129 SECTION OR BLOCK NO. 14

House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	( )	No	( )	
Auto. Dishwasher	Yes	( )	No	( )	
Auto. Wash. Machine	Yes	( )	No	( )	
Site Suitable	Yes	( )	No	( )	

Character & Porosity of Soil Sandy loam Sandy loam


Percolation Rate 2 min/inch

Topography Slight slope

Depth to Water Table 48"+

Rock or other impervious formations None

Lot Area 1 acre



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 300 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public ( )

(Town water available)

Installed by Sam Osborne

IMPROVEMENTS PERMIT BY T. C. Thomas

COMMENTS: _____

CERTIFICATE OF COMPLETION BY T. C. Thomas DATE 4/10/01

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold