DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Jim McDonald APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 9-2-05
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: Perth Rd N TL Liva Ln on Left near end PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well Existing ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	linear sideslope 11%	0-10	1 sbk l	fr ss/sp se		48			PS .3
		10-15	1 sbk cl	fr ss/sp se					
		15-34	1 sbk c	fr ss/sp se					
		34-48	1 sbk cl	fr ss/sp se					
2		0-10	1 sbk cl	fr		48			.3
		10-26	1 sbk c	fr ss/sp se					
		26-36	1 sbk cl	fr					
		36-38	1 sbk cl + sap	fr					
	BC	38-48	1 + sl/l sap						
3	10% 50+ feet from front of house	0-28	1 sbk cl	fr	1 spot chroma 3 of 2% of profile	48			.3
		28-36	1 sbk c	fr ss/sp se					
		36-42	1 sbk cl	fr					
		42-48	1 + sl/l sap	fr					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Judy Mowrer
OTHER(S) PRESENT: _____