DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___


SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Shavender Dev Garg — APPLICANT: ___
ADDRESS: ___ — APPLICATION DATE: ___ — DATE EVALUATED: 10-18-04
PROPOSED FACILITY: SFR — PROPOSED DESIGN FLOW (.1949): 480 gpd — PROPERTY SIZE: ___
LOCATION OF SITE: Lot 12 Northington Woods — PROPERTY RECORDED: ___
WATER SUPPLY: ☑ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-3	gr brn scl	fr sssp					.3
		3-8	wk sbk rdsh brn c	fr sp sop					
		8-24	(B-C) wk sbk yr scl	fr sss po					
		24-53	massive l/sl sap	fr sss po					
2	15% L	0-11	wk sbk brn scl	fr sss po					.3
		11-35	wk sbk RC	fr sss po sp					
		35-53	wk sbk yel brn cl/scl	fr sss po sl/scl sap					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	PWM 25% Red.	LPPBPS
Site LTAR	.3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: [illegible]
OTHER(S) PRESENT: Paul Pennington



SHEET 1 OF 4
TAX ID: 4639-64-0340
FOR SOURCE OF TITLE REFER TO D.R.
EXHIBIT MAP PREP
TONEY C. JAC