DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Shoranda Nat Grp APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 10-14-04
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 440 gpd PROPERTY SIZE: _____
LOCATION OF SITE: Lot 14 Northington Woods PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	10% + L	0-3	gr fri sl	fri					.3
		3-37	wk fabk rc/cl	fr ss sp sap					
		37-50	wk fabk mott cl/sl	fr ss sp fr ss sp					
2		0-5	gr wk fabk fri sl	fr ss sp					.3
		5-35	wk fabk rc	fr ss sp sap					
		35-46	wk fabk rc cl	fr ss sp few cem/sap					
3		0-7	gr fri sl	fr ss sp					.25
		7-33	wk fabk rc	fr ss sp sap					
		33-47	wk mod fabk rc/cl sl	fr ss sp sap	few common manganese conc top common/few/med, few fine/med appar mois				
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	LPP RRBS	LPP RRBS
Site LTAR	.125-.3	.25-.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: DHH
OTHER(S) PRESENT: _____