DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Shavender Dev Garg APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 10-18-04
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 4 BR appd PROPERTY SIZE: _____
LOCATION OF SITE: 1679 Northington Woods PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

(#3) 0-11 gr-wk Sbk brn sdl fr sss p
11-30 gr Sbk Rcl fr sss p
30-56 wk Sbk/Mpl cl fr sss p

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-7	wk Sbk brn sdl	fr sss p	common distinct few ch				(4)
		7-38	mod Sbk RC	fr SP SOP					
		38-48	wk Sbk Rcl	fr sss p	few ch prominent				
2	12% V	0-9	wk Sbk brn sdl	fr sss p					.3
		9-32	mod Sbk RC	fr SP SOP					
		32-48	(BC) wk-Sbk Rcl	fr sss p	few mtl				
3		0-16	wk Sbk brn sdl	fr sss p					.3
		16-39	wk Sbk RC	fr sss p SOP					
		39-53	wk Sbk ypsl	fr sss p	few fine mpp				
4	21% V	0-8	wk Sbk brn sdl	fr sss p					.3
		8-36	mod Sbk RC	fr sss p SOP					
		36-50	wk Sbk Rcl	fr sss p	few mtl mpp				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	LPP BPS	LPP BPS
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: [signature]
OTHER(S) PRESENT: Paul Hemmingsen


C8
C9
C10
C11
S72°54'46"E
(77.63')
NORTH
60'
DRIVE
112m
9mx9
℄ OF BRANCH
C09
C09
C09
436.14'
446.40'
480.39'
531.28'
LOT 8
59,381 sq.ft.
1.363 acres
LOT 9
53,691 sq.ft.
1.337 acres
LOT 10
58,221 sq.ft.
1.337 acres
N 35°22'59" E
N 31°01'38" E
N 27°06'33" E
(171.00')
N47°55'27"W
(136.00')
(136.00')
PIN 4639-53-3500
H. HAL and
WINIFRED K. HOLTON
D.B. 580, PG. 617
MTN. IS. DWG. NO. 260
ZONING