Northington Woods
L 60



Autry Concrete Products
8918 Byrum Dr Charlotte N.C. 28217
704-357-1250 704-357-1249
Certified Operator License # 28443



INSPECTION OF ENGINEERED SUBSURFACE WASTEWATER SYSTEM

Location 125 Whispering Cove CT Mooresville NC
Owner Address Phone DAVID G ASCOCK 704-340-6355
Remarks

ESTABLISHMENT:
Type, size, and sewage flow in accordance with permit? yes

2. COLLECTION SYSTEM:
Evidence of leaks into or out from sewer lines/manholes? NO
Free of blockages/solids buildup in lines or manholes? Yes

3. TANKAGE (Grease Trap/Lift Stations/Septic/Holding Tanks):
Tank risers accessible and surface water diverted? NO
Tanks and access manholes structurally sound, watertight? yes
Sanitary tee(s) in good working condition? yes
Tanks pumped, cleaned out as needed? yes

4. RAW SEWAGE LIFT STATION (if present):
Required pumps present, operating, and cycling properly? N/A
High-water alarm present and operating properly? N/A
Floats/pipe/valves/disconnects in good working condition? N/A
Control panel enclosure/components in good condition? N/A

5. EFFLUENT DOSING SYSTEM:
Effluent appears clear, free of excess solids? Yes

PUMP SYSTEMS:
Required pumps present, operating, and cycling properly? yes
High-water alarm present and operating properly? yes
Floats/pipe/valves/disconnects in good working condition? yes

Control panel enclosure/components in good condition? YES

Elapsed time readings: N/A

6. GROUND ABSORPTION FIELDS:

No evidence of effluent surfacing/reaching surface waters? NO

Surface water being effectively diverted away? NO

Diversions/ditches/swales/tile drains properly maintained? NO -

Line cover/vegetation adequate/maintained as needed? NO

Protected from traffic, destructive uses? YES

Distribution devices in good condition, working properly? YES

Repair area properly reserved, maintained? YES

LOW-PRESSURE PIPE DRAIN FIELDS:

Turnups/cleanouts/valves intact and accessible? YES

No effluent standing in lower laterals? NO

Laterals free of excess solids, cleaned out as needed? YES

Pressure head is properly adjusted? YES

OVERALL CONDITION AND OPERATION OF SYSTEM: GOOD

SUMMARY OF IMPROVEMENTS NEEDED:

Improvement Repair Within (Days)

WATER STANDING ABOVE TANKS FROM PATION DRAIN OR LEAK IN IRRIGATION SYSTEM. NEED TO MAINTAIN VEGETATION ON FIELD AREA FRENCH DRAIN FROM PATIO NEEDS TO BE DIVERTED AWAY FROM TANK AREA - BUSHES SURROUNDING CONTROL PANEL KEPT TRIMMED TO ALLOW ACCESS

Owner Responsibilities

*NEED TO PUMP TANK WITHIN THE YEAR.

DATE: 8-19-08

AGENT

INSPECTION AND MAINTENANCE AGREEMENT

STATE OF NORTH CAROLINA

COUNTY OF IREDELL

This agreement is made and entered into this 23rd day of April, 2008 by and between DAVID GLASSCOCK (hereinafter referred to as the "Owner") and Autry's (hereinafter referred to as the "Contractor").

WITNESSETH

WHEREAS, the Owner owns or controls the property upon which a ground absorption sewage treatment system (hereinafter "system") is installed, such system being designated a Type IV system under the Rules for Sanitary Sewage Collection, Treatment and Disposal found at 15A N.C. Administrative Code 18A.1900 et seq.; and

WHEREAS, 15A N.C. Administrative Code 18A.1961 requires a contract to be executed between the system owner and a management entity prior to the issuance of an Operation Permit for said system; and

WHEREAS, 15A N.C. Administrative Code 18A.1961 requires that a condition of the Operation Permit for said system be that a properly executed contract between the system owner and a management entity, shall be in effect for as long as the system is in use; and

WHEREAS, the Contractor is a management entity, of a type authorized by 15A N.C. Administrative Code 18A.1961 to manage a Type IV system.

NOW THEREFORE, in consideration of the premises and of the mutual covenants and promises contained in this Agreement, it is hereby agreed by and between the Owner and the Contractor as stipulated below.

1. The Contractor's Obligations. The Contractor shall perform the following services on the Owner's system located at
WHISPERING COVE CT. LOT #60 MOORESVILLE N.C.

a) The contractor shall inspect the system at least at the frequency, required in Table V(b) of 15A N.C. Admin. Code 18A.1961(b) for a Type IV System.

b) The Contractor shall perform the following routine maintenance procedures in accordance with the conditions of the Operation Permit:

1) [from operation permit]
2) INSPECT AND REPORT 2 TIMES PER YEAR TO IREDELL COUNTY HEALTH DEPT.
3)

c) The Contractor shall report the results of its inspections to the local health department at the frequency specified in Table V (b) of 15A N.C. Administrative Code 18A.1961(b) for a Type IV System.

d) If an inspection indicates the need for system repairs, the Contractor shall notify the local health

INSPECTION AND MAINTENANCE AGREEMENT

department within 48 hours of the inspection.

e) The Contractor shall notify the Owner of needed repairs, which are outside of the scope of routine maintenance described in subparagraph (b) above. The Contractors shall perform necessary repairs to the system at the request of the Owner and shall be entitled to payment therefor at the Contractor's normal charge for services and materials.

f) The Contractors shall employ or shall contract with a certified operator(s) if required by Table V (b) of 15A N.C. Admin. Code 18A.1961(b) for a Type IV System.

g) The Contractor shall respond to a request for a nonscheduled service or maintenance call within 24 hours after receipt of such request.

2. The Owner's Obligations.

a) The Owner shall pay to the Contractor the sum of $ 400.00 per year for periodic inspections, routine maintenance procedures and periodic reports. The annual fee may be amended upon sixty (60) days advance notice to the Owner but may not be increased more than 5 percent per year. The Owner shall pay to the Contractor his normal and customary fees for any work performed on the system as a result of nonscheduled service or maintenance calls. All fees are due and payable within thirty (30) days of billing. Payments due to the Contractor and unpaid by the Owner after thirty (30) days shall accrue interest from the due date until paid at a rate of 1.5 percent per month.

b) Within 10 days of receipt of notice of needed repairs pursuant to paragraph 1.e. above, the Owner shall request the Contractor to complete needed repairs or shall provide to the Contractor evidence that the needed repairs were satisfactorily completed by another entity.

c) The Owner shall provide the Contractor with such access to the system as is reasonably necessary for the Contractor to comply with the terms of this Agreement.

3. Term. This Agreement shall remain in effect until terminated.

a) Automatic Termination.
This agreement shall automatically terminate if the Operation Permit for the system is revoked and all appeals of the revocation are exhausted or the time for taking an appeal has passed.

b) Termination by Mutual Consent.
The Parties may mutually agree to terminate this Agreement by giving written notice of termination by mutual consent to the local health department thirty (30) days in advance of the date of termination.

c) Termination by the Owner.
The Owner may terminate this Agreement by giving notice to the Contractor and to the local health department thirty (30) days in advance of the date of termination.

INSPECTION AND MAINTENANCE AGREEMENT

d) Termination by the Contractor.

1) The Contractor may terminate this Agreement for cause by giving written notice of intent to terminate this Agreement to the Owner and to the local health department thirty (30) days in advance of the date of termination. Cause shall be defined as:

a) failure to remit payment for any bill for services performed under and in accordance with this Agreement if said bill is not paid within thirty (30) days of receipt by the Owner of the bill. If said bill is paid after notice of termination of this Agreement, the Agreement shall continue in effect; or

b) failure of the Owner to provide to the Contractor authorization to complete needed repairs or satisfactory evidence that needed repairs to the system were completed by another entity within 10 days of receipt of notice of needed repairs pursuant to paragraph 1.e. above. If said authorization to complete needed repairs or evidence of completion of said repairs is provided after notice of termination is given but prior to the date of termination of this Agreement, this Agreement shall continue in effect; or

c) failure of the Owner to allow the Contractor such access to the system as is reasonably necessary in order for the Contractor to comply with the terms of this Agreement.

2) The Contractor may not terminate this Agreement without cause, but may assign its rights and duties under this Agreement as provided in paragraph 4, below.

4. Assignment.

a) Assignment by the Owner.
The Owner shall notify the Contractor of the name and address of any purchaser of the property on which the system is located. The Owner shall also notify any purchaser of the property on which the system is located of the existence of this Agreement and shall assign all rights and duties under this Agreement to said purchaser.

b) Assignment by the Contractor.
The Contractor may assign its rights and duties under this Agreement to another management entity, which is qualified pursuant to 15A N.C. Admin. Code 18A.1961 to manage a Type IV system upon thirty (30) days written notice to the Owner and to the local health department.

5. Use of Subcontractors. The Contractor may subcontract with such manufacturers, suppliers and contractors as it deems desirable to perform any of the Contractor's duties under this Agreement. The Contractor shall at all times remain responsible for the performance of and payment for all work performed by all subcontractors.

6. Representations. The Parties represent to each other that each has the power, authority and legal right to enter into and perform its obligations as set forth in this Agreement.

INSPECTION AND MAINTENANCE AGREEMENT

7. Regulatory Amendments. References in this Agreement to sections of the Administrative Code shall include such rules as they may be amended in the future.

8. No Implied Waiver. The waiver by either Party, of the default or a breach by the other Party of any provision of this Agreement shall not operate or be construed to operate as a waiver of any subsequent default or breach. The failure at any time of either Party to enforce any provision of this Agreement (a) shall not be construed to be a waiver of such provisions, or of any other provision; and (b) shall not in any way affect the validity of this Agreement, or any part of this Agreement, or the right of either Party thereafter to enforce each and every provision of this Agreement.

9. Notice. Every notice required under this Agreement shall be in writing and shall be deemed sufficiently given if delivered in person or sent by certified or registered mail, return receipt requested, postage prepaid to the Party to be notified and addressed as follows:

To the Owner: DAVID GLASSCOCK
WHISPERING COVE CT LOT 60
MOORESVILLE NC

To the Contractor: Autry's

To the Local Health Department: IREDELL CO. HEALTH DEPT.

The date of any Notice shall be the date of personal delivery or the date shown on the return receipt as the date of delivery or attempted deliver, as the case may be. Changes in the respective addresses to which notice may be directed may be made from time to time by either Party by notice to the other party.

10. Place of Agreement. This Agreement and any questions concerning its validity, the system construction or performance shall be governed by the laws of the State of North Carolina. notwithstanding the place of execution, or the order in which the signatures of the Parties are affixed.


11. Entire Agreement and Amendment. This Agreement supersedes all prior negotiations, agreements and understandings between the Parties with respect to the subject matter hereof and constitutes the entire Agreement between the Parties with respect to the subject matter hereof. To be effective, any amendment or modification to this Agreement must be in writing and must be signed by the Parties.

12. Severability. In the event that any provision of this Agreement shall, for any reason, be determined to be invalid, illegal or unenforceable in any respect, the Parties shall negotiate in good faith and agree to such amendments, modifications or supplements of or to this Agreement or such other appropriate actions as shall, to the maximum practicable in light of such determination, implement and give effect to the intentions of the Parties as reflected in this Agreement, and the

INSPECTION AND MAINTENANCE AGREEMENT

other provisions of this Agreement shall, as so amended, modified, supplemented or otherwise affected by such actions, remain in full force and effect.

IN TESTIMONY WHEREOF, the Parties hereto have executed this Agreement in duplicate originals, one of which is retained by each of the Parties, the day and year first above written.



(Owner)

Attest:

_____

Steve Autry

(Contractor)

Attest:

Caroline Christian