VISION OF ENVIRONMENTAL HEALTH:
-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 5/13/03
PROPOSED FACILITY: House PROPOSED DESIGN FLOW (.1949): 480 GPD PROPERTY SIZE: _____
LOCATION OF SITE: Lot 31 Phase NORTHWOOD PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
LS ~CC 5-17%	0-8	GR / mic cl	FR - SS - SP MR	PS / 4R				
	9-27	SBK / cl	FR SS - SP R	PS / R				
	28-31	GR SAP	VFR - SS - NP	wet				
	32-48	GR cl	VFR SS - NP R	PS / R-4R				
CV 8-4%	0-30	SBK / mcl	Fl inc ~FR SS - SP	/ R				
	31-41	F GR / cl	FR - S - SP	PS / 4R				
	41-49	GR / SCL	VFR SS - NP	PS / 4R				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
uilable Space (.1945)		
tem Type(s)		
LTAR		

OTHER FACTORS (.1949): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____