IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Brock DATE 4-8-75 PERMIT NO. 63

PHONE: Business _____ Home 487-6014

LOCATION 150 W TR on 1303 3mi. TL on 1403 1mi on right S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 141 SECTION OR BLOCK NO. 16


House (4) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (4)	
Auto. Dishwasher	Yes ( )	No (4)	
Auto. Wash. Machine	Yes ( )	No (4)	
Site Suitable	Yes (4)	No ( )	

Lot Area 3/4 acre

Character & Porosity of Soil Sandy Clay loam Poros. Good
Percolation Rate Not Tested
Topography 3 to 5% Slope
Depth to Water Table 12 ft
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 225 Linear Ft. 450
Depth of Stone in Lines 20
Water Supply: Individual (4)
Public ( )

Installed by Sam Osteen

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 4-8-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold