DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: [illegible]
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Kent Prop. Dev. APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 2-23-05
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 480 gpd PROPERTY SIZE: ___
LOCATION OF SITE: Lot 40 Bay Pressure PROPERTY RECORDED: ___
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-10	wk sbk scl	fr ss sp					.3
		10-41	sbk cl	fr ss sp sap	few w. rock				
		41-48	wk sbk cl	fr ss sp	few w. rock, few mott sap				
2	16% L	0-20	wk sbk fr sdy scl	fr ss ss p					.3
		20-42	sbk, rc	fr ss ss p, few w. rock					
		42-56	wk sbk gr cl	fr ss sp	few mott sap				
3		0-9	gr wk sbk fr sdy scl	fr ss p					.2
		9-36	wk sbk gr cl	fr ss sp					
		36-98	wk sbk gr cl	fr ss ss p	few w. rock, common mica sap				
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	R	R
System Type(s)	Pon 25% Red	LPP BPS
Site LTAR	.3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): R
EVALUATED BY: [signature]
OTHER(S) PRESENT: Kathleen, TCJ


L227
L235
L211
L210
L164
L140
L188
L187
39
40
41
42
DRIVE
DRIVE
DRIVE
DRIVE
DRIVE
DRIVE
DRIVE
IORE LOOP
TD
TD
TD
TD
TD
TD
TD
TD
TD
TD
13+00
14+00
15+00
16+00
IBLIC R/W