DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____


SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Shoreline Bldg. APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 11-17-04
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 4 bdrm PROPERTY SIZE: _____
LOCATION OF SITE: Lot 46 Whitlington woods PROPERTY RECORDED: _____
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	9% V	0-27	WKfSbk/Pbrn sl/sl	fr ss sp					.3
		27-42	mfSbk RC	fr SSP SeSP					
		42-54	WKfSbk YR CL	fr ss sp	few common in SP				
2		0-2	brn sl	fr					.3
		2-30	MfSbk RC	fr ss sp SeSP					
		30-51	(B-C) WKfSbk yr L	fr ss sp	few faint ds SL SP				
3		0-6	gr brn sl	fr ss sp					.3
		6-23	MfSbk RC	fr ss sp SeSP	common in SP				
		23-32	(B-C) WKfSbk yr L	fr ss sp					
		32-56	marine ysl SP	fr ss sp					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	LPPPBPS	LPPPBPS
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: DH
OTHER(S) PRESENT: Brad Newman


LOT 48
31,520 sq.ft.
0.724 acres
LOT 47
31,339 sq.ft.
0.719 acres
LOT 46
27,934 sq.ft.
0.641 acres
LOT 45
29,905 sq.ft.
0.687 acres
255.78'
155.14'
113.15'
198.37'
148.89'
120.18'
60' R/W
150.74'
(150.00')
(245.59')
652.42'
S80°42'16"W
N14°08'00"W
S14°08'00"E
S13°51'13"E
N81°31'10"W
Well
60x40
60²
209
C45
C46
C47
C48
C49
C50
C51
C68
C69
L7
L11