DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ____ of ____
PROPERTY ID #: ____
COUNTY: ____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Stevenden Dev Corp. APPLICANT: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: 11-17-04
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 480gpd PROPERTY SIZE: ____
LOCATION OF SITE: Lot 52 Nottingham Woods PROPERTY RECORDED: ____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other ____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-4	gr brnsl	fr					.3
		4-20	mfsbk rc	fr sso sop					
		20-34	wk fsbk rc	fr sso sop					
		34-54	massive ls/sl	fr sso sop					
2	11%	0-9	gr brnsl	fr sso p					.3
		9-30	mfsbk rc	fr sso sop					
		30-52	wk fsbk R-yrd	fr sso p Lparentsap					
3		0-4	gr brnsl	fr sso p					.3
		4-26	mfsbk rc/cl	fr sso sop					
		26-49	wk fsbk yrl (B-C)	fr sso p commonsandsap					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	gpm 25% Red.	LPPPBPS
Site LTAR	.3	.3

OTHER FACTORS (.1946): ____
SITE CLASSIFICATION (.1948): BS
EVALUATED BY: [signature] IP
OTHER(S) PRESENT: Paul Pennington

LOT 58
10,842 sq.ft.
.938 acres
60²
55' MBSL
well
DRIVE
C61
C80
C59
C55
C54
C53
C64
C63
L10
60' R/W
S 73°15'58" W
LOT 50
LOT 51
32,877 sq.ft.
0.755 acres
60²
S 82°37'25" W
60²
LOT 52
41,811 sq.ft.
0.960 acres
COURT
75' MBSL
60²
323.15'
(12.84')
(59.00')
328.26'
221.88'
S78°48'40"W
(75.00')
(160.00')
S00°43'47"W
RAILROAD TRACK
SECTION (F)