DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Bay Crossing Ph 2 APPLICANT: Heart Prop LLC
ADDRESS: lot 125 APPLICATION DATE: _____ DATE EVALUATED: 5-24-
PROPOSED FACILITY: House PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L	0-5		fr ss/so		43+	—	—	PS .3
		5-43	red c/cl						
			m sbk	fr ss/so					
				se					
2	L	0-6	br scl wsbk	fr ss/so		45+	fi 32+	—	PS .3+
		6-32	red c msbk	fr ss/so					
		32-45	red cl wsbk	fr ss/so					
				se					
3	L/N	0-5	Br scl gr/sbk	fr ss/so		46+	fi	—	PS .3+
		5-46	red c/cl	fr ss/so					
			m sbk						
				se					
4	L/N	0-5	Lr scl br	fr ss/so		46+	fi 28+	—	PS .3+
		5-28	red lvg cl msbk	fr ss/se					
		28-46	yel red cl wsbk	fr ss/so					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: PSD