DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Heckle Properties Inc APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 2/6/05
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 480gpd PROPERTY SIZE: ___
LOCATION OF SITE: Lot 62 Foxy Crossing PROPERTY RECORDED: ___
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

(4) 0-6 wksbk fr ssp
6-35 ABK RC fr ss sp .3
35-52 wksbk cl fr ss p fav mi sap

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-6	wksbk fr sl cl	fr ss sp					.3
		6-25	ABK RC	fr ss sp st sp					
		25-52	wksbk RCL	fr ss sp fav mi mu sl sp					
		52-60	massive LSM	fr ss p					
2	South wall	0-4	wksbk fr sl cl	fr ss sp					.3
		4-13	wk ABK RC	fr ss p					
		13-28	wk sbk yb sl cl	fr ss sp common many mi sl sp					
		28-56	massive SLSM	fr ss p fav mi cl					
			100' minimum well radius						
3	North wall	0-8	mgr fr sl cl	fr ss sp					.3
		8-39	ABK RC	fr ss sp st sl p					
		39-48	wksbk RCL	fr ss sp common mi sl sp					
		48-52	Rock fr sp	mi					
4		0-4	gr fr sl cl	fr ss sp					.3
		4-24	mksbk RC	fr ss ss sp st sp					
		24-52	wksbk RCL	fr ss sp fav mi sp					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	PM 25% Red	LPP/PM 25-50% Red
Site LTAR	.3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: DH Lemon
OTHER(S) PRESENT: Kathleen J TCS Assn

178.00'
141.00'
210.42'
62
63
258.86'
290.75'
112.07'
well
Drive
108.00'
well
Drive
114.31'
well
42.08'
well
Drive
74.11'
45.88'
well
Drive
79.47'
well
Drive
109.91'
well
Drive
130.60'
well
Drive
286.67'
374.88'
68.88'
38
37
Goz