DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Hewett Prop. Clive — APPLICANT: _____
ADDRESS: _____ — APPLICATION DATE: _____ — DATE EVALUATED: 3-16-05
PROPOSED FACILITY: SFR — PROPOSED DESIGN FLOW (.1949): 480gpd — PROPERTY SIZE: _____
LOCATION OF SITE: Lot 57 Bay Crossing — PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTA
1	16-17% L	0-10	MSBk RC	fr SSSP SO/P					
		10-47	WKSBk type of	fr SSP common yw.		rock & fr sap			.25
		47-60	massive LSAP	fr SSP		pred soil			
2		0-2	gr fr Sd						
		2-27	MBk, RC	fr SSSP SO/P					.3
		27-49	wk SBk RCL	fr SSP					
		49-55+	massive LSAP	fr SSP					
3	3-9%	0-4	wk gr light brn SL	fr SSP					
		4-29	gr SBk	fr SSP SO/P					.3
		29-54	gr SBk	fr SSP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Conv 25% Red	25-50% Red
Site LTAR	.25	.25-.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: DH Hunter
OTHER(S) PRESENT: Paul Pennington