DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: 100
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Heckt Properties Inc. APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 2-16-05
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 4Bdrm PROPERTY SIZE: ___
LOCATION OF SITE: Lot 61 Bay Crossing PROPERTY RECORDED: ___
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	9% S	0-4	sbk fsnd	frssp					.3
		4-15	mfsbk RC	frsssp SOHP					
		15-55	wkfsbk RCL	frsssp	few gravels, rock, fair inf/perc				
2		0-10	wkfsbk scl	frssp					.3
		10-42	ABK RC	frsssp SOHP					
		42-52	wkfsbk RCL	frsssp	Restrictive horizon for conventional				
3		0-3	gr fsnd sl	frssp					.3
		3-39	mfsbk RC	frsssp SOHP					
		39-52	wkfsbk ygrcl	frssp	common mica/perc				
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	25	25
System Type(s)	Conv 25% Red	Same
Site LTAR	.3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): SC
EVALUATED BY: DM
OTHER(S) PRESENT: KS, Dean J, TC