DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Bells Crossing LLC Lot 76 APPLICATION DATE _____
ADDRESS: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ❑ Private ❑ Public ❑ Well ❑ Spring ❑ Other _____
EVALUATION METHOD: ❑ Auger Boring ❑ Pit ❑ Cut TYPE OF WASTEWATER: ❑ Sewage ❑ Industrial Process ❑ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	P76A L/C 1-10%	0-21	RC mmsbk	FrSSSP SEP	- msap	35	PS	-	PS 0.3 - 0.35
		21-35	RYcl mwsbk	" " " "					
		55-60	very l mass	" " " "					
2	P76B L/C 1-10%	0-14	BR scl mwsbk	Fr SSSP SEP	- vfr, mfr - esap	48	-	-	PS 0.3
		14-32	RB scl mmsbk	" " " "					
		32-48	RY scl mwsbk	" " " "					
P76C 3	SS 5-10%	0-10	B CL WFSBK	SS, SP, Fr SEP	- few/com fm fr - 48	48+	-	-	PS .25-.275
		10-33	B C WFSBK	" " " "					
		33-48	BRC WFSBK	" " " "					
P76D 4	SS 5-10%	0-6	RB SL Gr	SS, SP, Fr SEP	- com sap incl few wk ind	48+	-	-	PS .2
		6-28	R C MASBK	" " " "					
		28-48	R CL WFSBK	" " " "					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

COMMENTS: _____

DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Bells Crossing LLC Lot 76 APPLICATION DATE _____
ADDRESS: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ❑ Private ❑ Public ❑ Well ❑ Spring ❑ Other _____
EVALUATION METHOD: ❑ Auger Boring ❑ Pit ❑ Cut TYPE OF WASTEWATER: ❑ Sewage ❑ Industrial Process ❑ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	P76A L/G 4-8%	0-21	RC mmsbk	FrSSSPSEXP					PS
		21-35	RYcl vwsbk	" " " "	msap	35	PS	—	0.3 -
		55-60	very l mass	" " " "					0.35
2	P76B L/G 6-10%	0-14	BR scl vwsbk	FrSSSPSEXP					PS
		14-32	RB scl vwmsbk	" " " "	vf WR	48	—	—	0.3
		32-48	RY scl vwsbk	" " " "	esap				
P76C 3	SS 5-10%	0-10	B CL WFSBK	SS SP FR SEP	—	48"	—	—	PS
		10-33	B C WFSBK	" " " "	few/com fra				
		33-48	BRC WFSBK	" " " "	few FB				.25-.275
P76D 4	SS 5-10%	0-6	RB SL Gr	SS SP FR SEP	—	48"	—	—	PS
		6-28	R C MASBK	" " " "					
		28-48	R CL WFSBK	" " " "	com sap incl few WR incl				.3

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

COMMENTS: _____