IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 152007 PIN # 4639 74 9292 DATE October 19, 2010

OWNER or APPLICANT Bells Crossing LLC / Mike Ryon PHONE: Business 704-361-1084 Home:

OWNER or APPLICANT ADDRESS 127 B Promenade Dr. Mooresville

LOCATION / DIRECTIONS Perth Rd N TL Bells Crossing Dr. on left 229 Bells Crossing

SUBDIVISION Bells Crossing BLOCK / SECTION LOT # 199 LOT AREA .65Ac. DESIGN FLOW 480gpd L.T.A.R. .275gpd/ft²

Septic Tank 1000 Gallons: STB 825 Date 9-8-10

Pump Tank Gallons: P T Date

Pump Make Model Serial #

Nitrification Field No Fields 1 No Lines 5 Linear Feet 436

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type I (II) III IV V VI

System Description: 25% Reduction Gravity

Repair System Description: LP PPBPS

Maintenance Agreement Required ☐ YES ☐ NO

☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 4

☐ Business No. Persons 8

☐ Other No. Employees

☐ Slab ☒ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☒ Community

Comments / Conditions

Upstairs bonus room must have cased opening

Comments / Conditions 10/25/2010 Checked tank & 4 lines

10/29/2010 Checked 4th line

INITIAL SITE SKETCH

See Plan From Michael Athanas & Associates Approved By ICHD

AS BUILT SKETCH

Installed Quick 4 essentially as shown.

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☒ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Date 10/20/10

Improvement Permit by: Judy Melville Date 10-19-10

Authorization to Construct by: Judy Melville Date 10-19-10

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: Wayne Hontz RS

Operation Permit by: Date: 10/29/2010

Existing System Inspected by: Date:

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant