IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 15255?

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4639834837

APPLICANT: MERITAGE HOMES OF NC APPLICANT ADDRESS: 7761 BALLANTYNE COMMONS PKWY STE 103 CHARLOTTE

SITE ADDRESS: 159 BELFRY LOOP MOORESVILLE PHONE: ALT. PHONE:

SITE DIRECTIONS: PERTH (N) - TL BELLS XING - TL BELFRY - ON LT

SUBDIVISION: BELLS CROSSING SECTION: LOT # 90 LOT AREA: .77 AC DESIGN FLOW: 480 L.T.A.R.: .3

Septic Tank	1000	(gal)	STB	7760	Date	9-28	☑ New System	☐ Repair	☐ Expansion	System Type: I II (III) IV V VI	
Pump Tank	1000	(gal)	PT	3163	Date	12-15	System Description:	PUMP OFFSITE 25% REDUCTION			
Pump Make	ZOELLER	Model	E165-D	Serial #			Repair System Description:	DRIP ONSITE			
# Nitrification Fields	1	# Lines	4	Linear Ft:	415		Maintenance Agreement Required:	☐ YES	☑ NO		
Trench Width	36"	Max. Trench Bottom Depth	36"	Gravel Depth	N/A			☐ GRAVITY	☑ PRESSURE		

☑ Residence ☐ Business ☐ Other ☐ Slab — No. Bedrooms: 4 — No. Persons: 8 — No. Employees: — ☑ Crawl Space ☐ Basement w/plumbing

Water Supply: ☐ Private ☐ Public ☑ Community ☐ Basement w/o plumbing

Comments / Conditions: DO NOT ISSUE AC UNTIL EASEMENT IS RECORDED PROPERLY.

3/14/14 Checked Supply from PT to THP at street. MP

INITIAL SITE SKETCH

SEE BASEMAN CIVIL

SURVEY'S PLAN

AS BUILT SKETCH

CHECKED MAR 11 2014

REVIEWED NEW FLOOR PLAN 12-6-13 BA

CHECKED LINES TANKS BA PM

SET 2' PH 4-9-14 BA

Electrical Checked MP 5-6-14

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☑ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☒ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 10-1-13 Installed by: CPC

IMPROVEMENT PERMIT by: Date: 8/5/13 OPERATION PERMIT by: Date: 5-6-14

AUTHORIZATION TO CONSTRUCT by: Date: 11-8-13 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK