IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 152558

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4639835848

APPLICANT: MERITAGE HOMES APPLICANT ADDRESS: 7761 BELFRY LOOP MOORESVILLE

SITE ADDRESS: 153 BELFRY LOOP MOORESVILLE 28117 PHONE: ALT. PHONE:

SITE DIRECTIONS: PERTH RD (N) - TL BELLS XING - TL BELFRY - ON LT

SUBDIVISION: BELLS CROSSING SECTION: LOT # 91 LOT AREA: .82 AC DESIGN FLOW: 480 L.T.A.R.: .3

Septic Tank 1000 (gal) STB 720 Date 5-4
Pump Tank 1000 (gal) PT 363 Date 5-25
Pump Make ZOELLER Model E/Q Serial #
Nitrification Fields 1 # Lines 7 Linear Ft: 410
Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth N/A

☑ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI
System Description: PUMP 25% RED. OFFSITE
Repair System Description: PREP ONSITE
Maintenance Agreement Required: ☐ YES ☑ NO
☐ GRAVITY ☑ PRESSURE

☑ Residence ☐ Business ☐ Other ☐ Slab ☑ Crawl Space ☐ Basement w/plumbing
No. Bedrooms 4 No. Persons 8 No. Employees
☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☑ Community

Comments / Conditions: DO NOT ISSUE AC UNTIL EASEMENT IS PROPERLY RECORDED.
EASEMENT RECORDED 8/30/13

INITIAL SITE SKETCH

SEE BATEMAN CIVIL SURVEY'S PLAN

AS BUILT SKETCH

INSTALLED 7C58' (406')
CHECKED LINES 10-29-13
CHECKED PM HOOKUP & TANKS 11-12-13
SET 2' PH 1-31-14
CHECKED ELEC. 2-18-14 BA

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☐ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☐ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 8/30/13 Installed by: CPC

IMPROVEMENT PERMIT by: Date: 8/31/13 OPERATION PERMIT by: Date: 2-18-14

AUTHORIZATION TO CONSTRUCT by: Date: 8/30/13 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK