IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 152561

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4639837961

APPLICANT: MERITAGE HOMES OF THE CAROLINAS APPLICANT ADDRESS: 7761 BALLANTYNE COMMONS CHARLOTTE NC

SITE ADDRESS: 141 BELFRY LOOP - MOORESVILLE NC 28117 PHONE: ALT. PHONE:

SITE DIRECTIONS: PERTH (N) - TL BELLS XING - TL BELFRY - ON CT

SUBDIVISION: BELLS CROSSING SECTION: LOT # 93 LOT AREA: .96 DESIGN FLOW: 480 L.T.A.R.: .35

Septic Tank	1000 (gal)	STB	7100	Date	7-12	☑ New System	☐ Repair	☐ Expansion	System Type: I II ☑III IV V VI	☑ Residence	No. Bedrooms 4	Water Supply
Pump Tank	1000 (gal)	PT	3103	Date	7-2	System Description:	PUMP OFFSITE 25% REDUCTION			☐ Business	No. Persons 8	☐ Private
Pump Make		Model		Serial #		Repair System Description:	LPPPRS - ONSITE			☐ Other	No. Employees	☐ Public
# Nitrification Fields	1	# Lines	5	Linear Ft:	373	Maintenance Agreement Required:	☐ YES	☑ NO		☐ Slab	☑ Crawl Space	☑ Community
Trench Width	36"	Max. Trench Bottom Depth	24"	Gravel Depth			☐ GRAVITY	☑ PRESSURE		☐ Basement w/plumbing	☐ Basement w/o plumbing	

Comments / Conditions: DO NOT ISSUE AC UNTIL EASEMENT IS RECORDED PROPERLY - EASEMENT RECORDED 8/30/13

INITIAL SITE SKETCH

SEE BATEMAN CIVIL

SURVEY'S PLAN.

AS BUILT SKETCH

CHECKED LINES 10-31-13

CHECKED PM & TANKS 11-12-13

Checked Pressure Head Setting - ok 1/17/14 wmj

Ck'ed Alarm - Okay 1/17/14 wmj

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☑ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☐ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 8/30/13 Installed by: CPC

IMPROVEMENT PERMIT by: Date: 8/13/13 OPERATION PERMIT by: William O. Johnson, REHS Date: 1/17/14

AUTHORIZATION TO CONSTRUCT by: Date: 8/30/13 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK