3:00

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 150968 PIN# ~~4639949671.000~~ 4639843733 DATE 6-18-08

OWNER OR APPLICANT J+S Custom Homes PHONE: Business 704-634-9094 Home

ADDRESS 137-D Promenade Dr. Mooresville NC 28117

LOCATION Perth Rd, TL Bells Crossing, corner of ST Sophia CT + Bells Crossing

SUBDIVISION Bells Crossing BLOCK / SECTION LOT 69 LOT AREA .71 SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. .275

Septic Tank: 1000 Gallons: STB 760 Date 5-3

Pump Tank: Gallons: PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1350' Linear Feet 450'

No Lines 4 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth —

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: Grav. 25% Red.

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☐ Yes ☒ No Initially

☒ Gravity ☐ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Persons

☐ Business No. Employees

☐ Other

Water Supply: ☐ Individual ☐ Public ☒ Community

Comments:/Conditions: * Follow plan specs

Comments:/Conditions:

INITIAL SITE SKETCH

See Attached Plan From Rollins Soil + Environmental Services

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plan valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 9/12/08 Installed by: Carolina Pipe

Improvement Permit by: date 6-18-08 Operation Permit by: date 8-27-13

Authorization to Construct by: date 5-16-13 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK