4639844495

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 150957 PIN# 4639 94 2671 . 195 DATE 6/12/08

OWNER OR APPLICANT KYON WEST DEVELOPERS PHONE: Business 704-361-1084 Home

ADDRESS 127 B PROMENADE DR. MOORESVILLE, NC. 28117

LOCATION PERTH RD N TL BELLSCROSSING TO ON L BEFORE LAST CULDESAC

SUBDIVISION BELLSCROSSING BLOCK / SECTION LOT 95 LOT AREA .85AC SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. .25

Septic Tank: 1000 Gallons; STB 1600 Date 7-6-12
Pump Tank: Gallons; PT Date
Pump Make: Model Serial No.
Nitrification Field: No Fields 1 Square Feet Linear Feet 480'
No Lines 4 Trench Width 3' Max Trench Bottom Depth 3' Gravel Depth No

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI
System Description: GRAVITY - 25% REDUCTION
Repair System Description: SAME TYPE
Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other
No. Bedrooms 4 No. Persons No. Employees

Water Supply: ☐ Individual ☐ Public ☒ Community

☒ Gravity ☐ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions: FAST TRACK DESIGN AND SPECS BY ROLLINS ENVIRONMENTAL SVCS 704-658-1723

Comments/Conditions: Uncovered Drainfield 1st line OK & 4th line OK 2nd & 3rd need reached 24" Okay

INITIAL SITE SKETCH

(1) PLAN MODIFIED + CALL ICHD BEFORE ATTEMPTING INSTALLATION

(2) COPY OF SITE PLAN + SPECS ONSITE DURING INSTALLATION

AS BUILT SKETCH

11/15/2012 Rechecked 2nd & 3rd line OK

Used Quick 4 Serial Dist (no Drop Boxes)

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: X date 9/12/08

Improvement Permit by: Wesley Sparks RS. date 6/12/08

Authorization to Construct by: REHS date 10-19-12

Installed by: Carolina Pipe Cleaning Cert# 3191

Operation Permit by: date 11/15/12

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK