IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 152018 PIN# ~~4639834045.206~~ 4639 845 220 DATE 8-14-08

OWNER OR APPLICANT Bells Crossing LLC PHONE: Business 704-663-1600 Home

ADDRESS 514 Williamson Rd Suite 421 Mooresville, NC 28117

LOCATION Perth, TL Bells Crossing, TL Beltry, on R

SUBDIVISION Bells Crossing BLOCK / SECTION 9 LOT 206 LOT AREA .69 AC SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. .2

Septic Tank: 1000 Gallons; STB Date

Pump Tank: [redacted] Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1830' Linear Feet 610'

No Lines 6 Trench Width 36" Max Trench Bottom Depth 27" Gravel Depth —

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: PM 25%

Repair System Description: Drip

Maintenance Agreement Required: ☐ Yes ☒ No Initially

☒ Gravity ☐ Pressure ☒ Slab ☒ ~~Crawl Space~~ ☐ Basement w/plumbing ☐ Basement wo/plumbing

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Persons

☐ Business No. Employees

☐ Other

Water Supply: ☐ Individual ☐ Public ☒ Community

Comments/Conditions: 1) Max trench bottom is 27" due to soil conditions 2) French drain must be installed as shown on lay out

Comments/Conditions:

INITIAL SITE SKETCH

See attached from Rollins Soil & Environmental Services

SEE MODIFIED SITE PLAN 2-19-13

HOOKED TOGETHER

AS BUILT SKETCH

FRENCH DRAIN OK 4-23-13 BEING REDRAWN TO FM.

CHECKED LINES & TANKS

SET 2' PM

CHECKED ELEC. & ALARM BA

TAP SIZES

150' = 3/4" 80
105' = 1/2" 40
75 & 70 = 3/4" 80
85' = 1/2" 80
125' = 1/2" 40

SEE REVISED PLAN SHOWING PRESSURE MANIFOLD

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 9/17/08

Improvement Permit by: date 8-14-08

Authorization to Construct by: date 2-19-13

Installed by: GPC

Operation Permit by: date 5-17-13

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK