2:00

# IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

## IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 152206 PIN# ~~4639-83-1045, 207~~ 4639 846 263 DATE 8/22/08

OWNER OR APPLICANT ~~RYAN WEST DEVELOPERS~~ Bells Crossing PHONE: Business 704-361-1084 Home

ADDRESS 127 B PROMENADE DR. MOORESVILLE, NC. 28117

LOCATION PERTH N TL BELLS CROSSING TL BELFRY TO 1ST lot on R BELOW AMENITIES AREA

SUBDIVISION BELLS CROSSING BLOCK / SECTION LOT 207 LOT AREA .66AC SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. .225

Septic Tank: 1000 Gallons: STB 760 Date 10-12-13
Pump Tank: Gallons: PT Date
Pump Make: Model Serial No.
Nitrification Field: No Fields 1 Square Feet 1599 Linear Feet 533
No Lines 5 Trench Width 3 Max Trench Bottom Depth 27" Gravel Depth N/A

[X] New System [ ] Repair [ ] Expansion System Type: I (II) III IV V VI
System Description: GRAVITY - 25% REDUCTION
Repair System Description: LP - PPBPS
Maintenance Agreement Required: [ ] Yes [X] No

[X] House/Mod. Home [ ] Mobile Home [ ] Business [ ] Other
No. Bedrooms 4 No. Persons No. Employees

Water Supply: [ ] Individual [ ] Public [X] Community

[X] Gravity [ ] Pressure [ ] Slab [X] Crawl Space [ ] Basement w/plumbing [ ] Basement wo/plumbing

Comments:/Conditions: FAST TRACK DESIGN, LAYOUT AND CALCULATIONS BY ROLLANS SOIL & ENVIRONMENTAL 704-658-1723

Comments:/Conditions:

INITIAL SITE SKETCH

(1) NO CHANGES WITHOUT WRITTEN APPROVAL FROM IREDELL COUNTY HEALTH DEPARTMENT

(2) INSTALLER MUST HAVE LAYOUT, SPECS. AND CALCULATIONS ON SITE DURING INSTALLATION

(3) NOTE MAXIMUM TRENCH DEPTH IS 27"

(4) SUBSURFACE INTERCEPT DITCHING REQUIRED ALONG ENTIRE RIGHT SIDE PROPERTY LINE. THIS SHOULD EMPTY ON BELFRY LOOP.

AS BUILT SKETCH

INSTALLED AS SHOWN

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration [ ] Improvement Permit with site plan valid for sixty months [X] Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: [signature] date 11/10/08 Installed by: RCP

Improvement Permit by: Wesley Sparks RS. date 8/22/08 Operation Permit by: [signature] date 4-10-13

Authorization to Construct by: [signature] date 9/13/13 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK